

Attestation of Conformity

No. N8A 072092 0296 Rev. 02

Holder of Certificate: Shanghai JA Solar Technology Co., Ltd.

No. 118, Lane 3111,
West Huancheng Road
Fengxian District
201401 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product:	Crystalline Silicon Terrestrial Photovoltaic (PV) Modules Mono-Crystalline Silicon Photovoltaic Module
-----------------	---

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.
It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704061604115-17

Date, 2019-04-26 (Zhulin Zhang)

gati



Product Service

Attestation of Conformity

No. N8A 072092 0296 Rev. 02

Model(s):

1500 V DC Maximum System voltage,

Fire Safety Class C Modules:

JAM6(K)-72-xxx/PR/1500V, xxx= 345 to 370 in step of 5;

JAM6(K)-60-xxx/PR/1500V, xxx= 285 to 310 in step of 5;

JAM6(K)-72-xxx/4BB/1500V, xxx= 320 to 345 in step of 5;

JAM6(K)-60-xxx/4BB/1500V, xxx= 265 to 285 in step of 5;

1500 V DC Maximum System voltage,

Fire Safety Class A Modules:

JAM72D00-xxx/BP, xxx= 330 to 385 in step of 5;

JAM60D00-xxx/BP, xxx= 275 to 320 in step of 5;

JAM60D00-xxx/PR, xxx= 285 to 320 in step of 5;

JAM72D00-xxx/PR, xxx= 340 to 385 in step of 5;

JAM60D00-xxx/MB, xxx= 310 to 315 in step of 5;

JAM72D00-xxx/MB, xxx= 370 to 380 in step of 5;

JAM72D09-xxx/BP, xxx= 360 to 385 in step of 5;

JAM60D09-xxx/BP, xxx= 300 to 320 in step of 5;

1000 V DC Maximum System voltage,

Fire Safety Class C Modules:

JAM6(K)-72-xxx/PR, xxx= 345 to 370 in step of 5;

JAM6(K)-60-xxx/PR, xxx= 285 to 310 in step of 5;

JAM6(K)-72-xxx/4BB, xxx= 320 to 345 in step of 5;

JAM6(K)-60-xxx/4BB, xxx= 265 to 285 in step of 5;

JAM72S02-xxx/PR, xxx= 345 to 390 in step of 5;

JAM60S02-xxx/PR, xxx= 285 to 325 in step of 5;

JAM72S02-xxx/SC, xxx= 320 to 365 in step of 5;

JAM60S02-xxx/SC, xxx= 265 to 305 in step of 5;

JAM72S02-xxx/MR, xxx= 365 to 385 in step of 5;

JAM60S02-xxx/MR, xxx= 305 to 320 in step of 5;

JAM72S08-xxx/PR, xxx= 360 to 395 in step of 5;

JAM60S08-xxx/PR, xxx= 300 to 330 in step of 5.

1000 V DC or 1500 V DC Maximum System voltage,

Fire Safety Class C Modules:

JAM72S01-xxx/SC, xxx= 320 to 365 in step of 5;

JAM60S01-xxx/SC, xxx= 265 to 305 in step of 5;

JAM72S01-xxx/PR, xxx= 345 to 390 in step of 5;

JAM60S01-xxx/PR, xxx= 285 to 325 in step of 5;

JAM72S01-xxx/MR, xxx= 365 to 385 in step of 5;

JAM60S01-xxx/MR, xxx= 305 to 320 in step of 5;

JAM72S03-xxx/PR, xxx= 360 to 395 in step of 5;

JAM60S03-xxx/PR, xxx= 300 to 330 in step of 5;

JAM72S09-xxx/PR, xxx= 370 to 390 in step of 5;

JAM60S09-xxx/PR, xxx= 310 to 325 in step of 5;

JAM72S10-xxx/PR, xxx= 380 to 400 in step of 5;

JAM60S10-xxx/PR, xxx= 315 to 330 in step of 5;

JAM72S10-xxx/MR, xxx= 390 to 400 in step of 5;

JAM60S10-xxx/MR, xxx= 325 to 335 in step of 5

xxx is standing for rated output power at STC

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 072092 0296 Rev. 02

Parameters:

Construction:	Framed or Frameless, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC or 1000 V DC
Fire Safety Class:	Class C or Class A according to UL790.

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TUV®